

www.pcipy.co.za

Head Office - Gauteng Tel: (011) 472 4444 Branch - Natal Tel: (031) 702 8386



Supplier of Control Instrumentation to the South African Electrical Industry

WQ 0217, WQ 1217, WQ 0207, WQ 2207, WQ 1247



Energy meters display instantaneous power in single and three-phase systems with balanced or unbalanced load. Accuracy classes are 1 for energy measurement (EN 61036), 1.5 for power measurement and 2.5 power factor measurement.

TYPE	WQ 0217	WQ 1217	WQ 0207	WQ 2207	WQ 1247
Front frame (mm)	96 x 96				
Cutting for mounting (mm)	92 x 92				
Scale length (mm)/ Number of counters	- / 1	-/2	95 / 1	125 / 1	- / 2 LCD
Voltage input 100 V, 110 V, 230 V, 400 V, 500 V					
Current input 1 A, 5 A					
1b,1br Single phase system	•	•	•	•	•
3b, 3br Three-phase three-wire balanced load system	•	(•8	•	•	
3u, 3ur Three-phase three-wire balanced load system	•	(8)	•		
4b, 4br Three-phase four-wire balanced load system	•	(•)	•		
4u, 4ur Three-phase four-wire unbalanced load system	•	•	•	•	•
Option					
One impulse output		•		(.*)	•
Two impulse outputs	7.0		•		
57 V, 110 V, 230 V, 400 VAC Auxiliary supply		•		730	